



**Massachusetts Bay
Transportation Authority**

DGM Remarks

Fiscal & Management Control Board

February 25, 2019



February 8, 2019 – Power Incident: Follow-up

- 02/08/19 power failure occurred at Lincoln switching station
- Affected Blue, Green and Orange Line signals in the Downtown core area.
- Emergency repairs underway to fix faulted cable and collapsed duct bank
- Project for full duct bank rebuild including building new redundant duct bank with cables in process.
- Power Modernization Study initiated with final report expected Summer.

